



DESIGN FACTORS FOR USE WITH AS 2566

Bedding constant, $R = 0.100$

Deflection lag factor, $L = 1.40$

50 year tensile creep modules, $E_c = 690 \text{ N/mm}^2$

Modulus of soil reaction, $E' = Y/(Dm/t) \text{ N/mm}^2$

Y factor = 83 N/mm^2



uPVC PIPE BEDDING DETAIL

DETAIL NO:

DS-7

**Design and Material Standards
MANUKAU WATER LIMITED**

UPDATED:

JULY 2006