



Rubber Ring Jointing system of an approved standard

The pipes shall comply with:

- (i) NZS/AS 1260 for 100mm.
- (ii) NZS/AS 1477 for 150mm.

It shall be coloured grey to NZS/AS 1260 and have the following identification as per NZS/AS 1260 in blue print.

- (i) For 100mm Supertuff:
IPLEX PIPELINES SUPERTUFF SEHC DWV 1500.ST.HD.100PVC.
AS/NZS 1260, year, month, day PN
- (ii) For 150mm Supertuff:
IPLEX PIPELINES SUPERTUFF SEHC SI PVC 150 PN9, year,
month, day PN AS/NZS 1477.

The following diameter and wall thickness shall comply with the following:

Nominal Diameter	Outside Diameter	Minimum Wall Thickness
100mm	110.2 ± 0.2mm	4.1mm
150mm	160.25 ± 0.25mm	6.3mm

Note:

Not to be used under carriageways.



SUPERTUFF, mPVC SEWER PIPE
(SIZE 100MM TO 150MM)

Design and Material Standards
MANUKAU WATER LIMITED

DETAIL NO:
MS-10

UPDATED:
JULY 2006