



### Notes:

1. The layout shall:
  - Have a maximum distance of 50m between the nearest meter bank and extreme of building.
  - Have meter bank(s) accessible in public areas.
2. The meter bank shall be installed at the time of subdivision with fittings and pipes up to the valve in the meter bank.
3. The extent of the public water supply shall be limited to the meters.
4. All ridermains and private service leads to be ducted.
5. Refer to the notes of drawing W5 for the selection of sluice valve SV1, SV2 and SV3.



### **WATER METER BANKS TYPICAL LAYOUT**

**Design and Material Standards  
MANUKAU WATER LIMITED**

DETAIL NO:

**DW-26**

UPDATED:

**JULY 2006**